

TABLE C1
CONCRETE AIR CONTENT PRICE ADJUSTMENTS

<u>Air Content Range</u>			<u>% Payment of Unit Price</u>
<u>Minimum</u>		<u>Maximum</u>	
1.1*	and	below	0%
0.6	to	1.0*	50%
0.1	to	0.5*	75%
Low air	tolerance	limit	100%
	Target		100%
High air	tolerance	limit	100%
0.1	to	0.5*	95%
0.6	to	1.0*	85%
1.1	to	1.5*	75%
1.6	to	2.0*	60%
2.1*	and	above	0%

* Air content deviation above or below the acceptable limits

TABLE C2
WATER CEMENT RATIO PRICE ADJUSTMENTS

<u>Water Cement Ration Range*</u>			<u>% Payment of Unit Price</u>
<u>Minimum</u>		<u>Maximum</u>	
0.051	and	above	0%
0.031	to	0.050	50%
0.021	to	0.030	70%
0.011	to	0.020	80%
0.001	to	0.010	90%
-----	Limit	-----	

* W/C deviation above the acceptable limits

TABLE C3
VIBRATOR FREQUENCY PRICE ADJUSTMENTS

<u>Vibrator Frequency</u>		<u>% Payment of Unit Price</u>
<u>Minimum</u>	<u>Maximum</u>	
below 3500		90%
3500	to 4999* 3999*	95%
5000 4000	to 8000	100%
8001	to 9000	90%
9001	to 10,000	75%
above 10,000		50%

* Engineer may extend the lower specification limit to include this range

Note: ~~Penalty~~ Price adjustment shall apply to area half the distance to the adjacent vibrator or edge of slab and the length traveled during the non-compliance

TABLE C4
CERTIFIED PLANT INSPECTION PRICE ADJUSTMENTS

<u>Type of Work</u>	<u>Daily Penalty</u>
Structural Concrete & Patching	\$ 500
Paving	\$1,000

Note: ~~Penalty~~ Price adjustment for failure to provide certified plant inspection. Partial days may be assessed

TABLE C5
LATE CURING APPLICATION PRICE ADJUSTMENTS

<u>Time After Finishing (hrs)</u>			<u>% Payment of Unit Price</u>
½	to	<1	90% 95%
1	to	<1½	80%
1½	to	<2	65%
2	to	<3	50%
More	than	3	0%