



NOTES

1. PROVIDE MINIMUM CONCRETE THICKNESS OF 6" AROUND PIPE.
TRENCH WALLS SHALL BE USED TO FORM CONCRETE.
2. MINIMUM CONCRETE STRENGTH SHALL BE 2,500 PSI BEFORE
FINAL TRENCH BACKFILL IS PLACED.
3. INSTALL AND SUPPORT PIPE AS SPECIFIED.

REV.	DATE	BY	P.C. CONCRETE ENCASEMENT	FIGURE: 3010.2
DATE: 01-01-98				SHEET 1 OF 1