



NOTES:

REINFORCED CONCRETE BEAM UTILITY LINE SUPPORT TO BE USED WHEN NEW SEWER EXCAVATION IS CROSSING UNDER AN EXISTING UTILITY LINE (SEWER LINES, WATER LINES, GAS LINES, ETC...) AS DIRECTED BY THE ENGINEER.

ALLOW CONCRETE TO CURE A MIN. OF 48 HOURS BEFORE COMPLETING BACKFILL.

SPECIAL DESIGN REQUIRED FOR TRENCH WIDTH GREATER THAN 7' OR TRENCH DEPTH GREATER THAN 15'.

			REINFORCED P.C. CONCRETE BEAM UTILITY LINE SUPPORT	FIGURE: 3010.5
REV.	DATE	BY		DATE: 01-01-98