



① PROVIDE A 1/2" EXPANSION JOINT AT THE BACK OF CURB. WHEN SPECIFIED, PROVIDE A KT-2 OR BT-3 JOINT BETWEEN THE SIDEWALK RAMP AND STREET PAVEMENT AND PLACE A 1/2" EXPANSION JOINT AT THE FIRST JOINT IN THE SIDEWALK BEYOND THE RAMP FLARES.

THIS DETAIL SHALL BE FOLLOWED WHENEVER SUFFICIENT RIGHT-OF-WAY IS AVAILABLE. IF SITE CONDITIONS DO NOT PERMIT USE OF THIS DETAIL, FIGURE 7030.11 MAY BE USED. CONTRACTOR SHALL FIELD VERIFY LAYOUT PRIOR TO CONSTRUCTION.

3	10/18/05		PREFERRED PEDESTRIAN RAMP WITHIN INTERSECTION RADIUS FOR CLASS "A" SIDEWALK	FIGURE: 7030.10
REV.	DATE	BY		SHEET 1 OF 1
DATE: 01-01-98				