


URBAN STANDARD SPECIFICATIONS for PUBLIC IMPROVEMENT MANUAL





SECTION A-A SIDEWALK AND CURB DROP FOR NEW PAVING



NOTES:

THIS DETAIL SHALL BE FOLLOWED WHENEVER SUFFICIENT RIGHT-OF-WAY IS AVAILABLE. IF SITE CONDITIONS DO NOT PERMIT USE OF THIS DETAIL, AS INDICATED BY TABLE 1, SEE FIGURE 7030.13A.

- ① COMBINATION RAMP: IF NORMAL SIDEWALK ELEVATION CANNOT BE ACHEIVED WITH RAMP BETWEEN STREET AND LANDING DUE TO LIMITED RAMP LENGTH, A COMBINATION RAMP MUST BE PROVIDED TO MAKE UP THE ELEVATION DIFFERENCE. THE LENGTH OF PARALLEL RAMP MAY VARY; HOWEVER, IT SHALL NOT BE REQUIRED TO EXCEED 15', REGARDLESS OF THE RESULTING SLOPE
- © PROVIDE A 1/2" EXPANSION JOINT AT THE BACK OF CURB. WHEN SPECIFIED, PROVIDE A KT-2 OR BT-3 JOINT BETWEEN THE SIDEWALK RAMP AND STREET PAVEMENT AND PLACE A 1/2 INCH EXPANSION JOINT ON EITHER SIDE OF THE LANDING.

REV.	DATE	BY	PREFERRED PERPENDICULAR RAMP	FIGURE: 7030.12
DATE: 10-18-05			WITHIN INTERSECTION RADIUS FOR CLASS "B" OR "C" SIDEWALK	SHEET 2 OF 2