

The intent of the plan is to provide steel guardrail posts on top of box culverts or similar situations when wood post embeddings are not possible.

All steel posts and connecting hardware necessary in the construction and installation of the adapter shall be galvanized.

Contractor may elect to fabricate posts using 6 foot post and adjusting in the field as follows:

- A. Saw off top end to proper length and drill new holes.
- B. The sawed end and drilled holes shall be treated with two coats of organic zinc rich paint containing at least 94% zinc dust. The surfaces to be treated shall be free of oil residues due to sawing or drilling.

The price bid for " Guardrail, Special Post Adapter Unit, RE-37" shall be full compensation for furnishing, assembling, and installing the adapter unit as shown.

Contract Items:

- Guardrail, Special Post Adapter Unit
- Installation of Guardrail



Incidental to adapter unit:

- 1 - 12" x 8 1/2" x 1/2" ASTM A36 Steel Plate
- 1 - 11" x 8 1/2" x 1/4" ASTM A36 Steel Plate
- 4 - 1" ASTM A307 Hex Head bolts with one nut and two washers per bolt

Incidental to Installation of Guardrail:

- W6 x 9 or W6 x 8.5 Steel Guardrail Post (variable length)
- 6" x 8" Wood Spacer Block (14" or 21.5" length)

Tabulation: 108-8B



- ① Bolt length equals slab thickness plus 2 inches. Field clip topside washers if necessary to clear weld.
- ② See Standard Road Plan RE-12C for steel guardrail post and blockout details.
- ③ Holes are to be made with equipment designed to cut through concrete and reinforcing steel.
- ④ Any spalling shall be grouted before placement of bottom plate. The grout shall consist of equal parts by weight of Portland cement and concrete sand, mixed with sufficient water to form a paste.

	REVISION 15 10-17-06	
	RE-37	
STANDARD ROAD PLAN		SHEET 1 of 1
REVISIONS: Show correct mounting height for thrie beam and reorganize dimensioning.		
<i>Deanna Macfild</i> APPROVED BY DESIGN METHODS ENGINEER		
GUARDRAIL SPECIAL POST ADAPTER UNIT		