



**Subject: Revision of Standard Road Plan Manual**

**Revision Date: 10/17/2023**

**To: Holders of Standard Road Plans**

**From: Design Bureau**

The following revisions are effective with the 10/17/2023 letting. Projects let prior to this date may reference earlier versions of these Standard Road Plans. Questions concerning information contained on the Standard Road Plans should be directed to the Methods Section, Design Bureau, telephone (515) 239-1830 or email [michael.thiel@iowadot.us](mailto:michael.thiel@iowadot.us).

**Standard  
Road Plan**

**Description of Revision**

---

**BA Index**

**BA-106**

Modified reinforcing to fit with 17' panels.

**BA-205**

Added note 3. Do not bolt rail to post #2 per manufactures instructions.

**BA-225**

Added note 3. Do not bolt rail to post #2 per manufactures instructions.

**DR Index**

**DR-201**

Added note about shape and dimensions.

**DR-202**

Added note about shape and dimensions.

**DR-205**

Added note about shape and dimensions.

**DR-206**

Added note about dimension and shape.

**DR-306**

Change from granular cap to top soil cap.

**EC Index**

**EC-603**

New. Replaces Detail 570-5.

**EC-604**

New. Replaces Detail 570-7.

## **EW Index**

**EW-501**

**Added Type D Entrance.**

## **PR Index**

**PR-103**

**Changed length of patch from 6'-10' to 4'-10' to match specs.**

**PR-105**

**Changed length of patch from 6'-10' to 4'-10' to match specs.**

## **TC Index**

**TC-61**

**Removed channelizer markers, Removed note about queue length. Added at grade intersection detail.**